

**SUPPLEMENT 3 TO EC-TYPE EXAMINATION CERTIFICATE  
VTT 08 ATEX 066**

Requested by:

**Centaurea Oy, FINLAND**

Apparatus:

**Portable luminaire**

Scope of the certificate:

With the dissipative end plates and the construction according to the drawing 10003\_1419kok with part list the certified equipment fulfill the requirements for the equipment group IIC and can be marked as



**II 2 G Ex e mb IIC T3 Gb  
II 2 D Ex t IIC T90 °C Db**

**IP 66/IP67**

**-20 °C ≤ Tamb ≤ +40 °C**

Test report:

Compliance with the requirements and material specification are recorded in the confidential test report no VTT-S-04588-10.

Espoo, 4.6.2010

**VTT Expert Services Ltd**

**Martti Siirola**  
Research scientist

**Risto Sulonen**  
Senior research scientist

